

Appendix B

Certified Validation Report Template, Part A: Provided by Validator

Audit Information:

Water Supplier Name: City of Exeter PWS ID: CA5410003

System Type: Potable Audit Period: 2019

Utility Representation: Daymon Qualls

Validation Date: 09/25/2020 Call Time: 8 am Sufficient Supporting Documents Provided: **Yes**

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 72 Data Validity Band (Level): Band IV (71-90)

ILI: 21.36 Real Loss: 258.13 (gal/conn/day) Apparent Loss: 7.63 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 36.7%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator : Garth A. Pecchenino, P.E. Qualifications: Water Audit Validator has past experience over 30 years of performing water audit reviews and validations

Validator Provided

Certified Validation Report Template, Part B: Provided by Utility

Water Supplier Name: City of Exeter

Water Supplier ID Number: CA5410003

Water Audit Period: 2017

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

City continues to address problematic areas in water distribution system with a history of multiple repairs.

City replaces old meters or meters with reading issues

City to preform a leak detection survey of the older water pipes and service locations for increased leakage amount over this audit year

City provides education to customers on leak repairs and reporting leaks to the City Water Department.

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (Print)

Executive Position

Signature

Date

Utility Provided